

DRINKING WATER NOTICE

Lagrange Village PWS Has Levels of Total Haloacetic Acids (HAA5) above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for Total Haloacetic Acids (HAA5). The average level of Total Haloacetic Acids (HAA5) over the last four quarters was 0.091 mg/L. The standard for Total Haloacetic Acids (HAA5) is 0.060 mg/L.

What should I do?

- **You do not need to use an alternative (e.g. bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

What is being done?

Upon being notified of the DBP exceedance on 04/01/24. DBP MCL violations are determined based on a Locational Running Annual Average (LRAA), not individual sample results, to clarify that these violations and public notices will be issued until the LRAA is below the MCL, not the sample result itself. We are also in contact with our water supplier, Rural Lorain County Water Authority, and the OEPA Division of Drinking and Groundwater Department. Again, "you do not need to use an alternative water supply. The levels detected do not pose an immediate risk to your health."

Additional information may be obtained by contacting:

Contact Person: Mary Kay Gates

Phone Number: 440-355-5555

Mailing Address: 301 Liberty Street, LaGrange Ohio, 44050

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: January 31, 2025

PWSID: OH4700603 Facility ID: DS1

Monitoring Period: Fourth Quarter of 2024